

EXHIBIT D

REQUIREMENTS FOR DECORATIVE, INFORMATIONAL & OTHER NON-CABLE ATTACHMENTS

DEFINITIONS

1. 'Attacher' – Any municipality, charity, community non-profit organization, business engaged in charitable or community benefit initiative, or a qualified contractor authorized to perform work on said organizations' behalf.
2. 'Cables' – For the purpose of these requirements, refers to any cable, wire rope, cord, guy or other tensile support for attachments.
3. Citizens' Electric Company – Also referred to as the 'Company'

GENERAL

4. Any rearrangement of Company facilities necessary to accommodate communication system attachments must be negotiated prior to making the attachment.
5. Bolt ends shall not project greater than one (1) inch beyond the nut.
6. In the event this "Exhibit D" does not fully address, specify or leaves ambiguity regarding the requirements for any given attachment, Attacher shall reference "Exhibit C - Requirements for Private Communications Systems Attachments," which is available on the Company's website.

IDENTIFICATION

7. Attachments shall not misrepresent their ownership.

ATTACHMENT MEANS AND POSITION

8. Any holes drilled entirely through the pole must maintain a minimum of two (2) inches, top edge to bottom edge, of vertical clearance from other holes.
9. Attachments shall remain in the same relative vertical order from one span to the next.
10. Attachment means and hardware must be approved by the Company.
11. Attachments shall not adversely impede the visibility of drivers or pedestrians.

12. Attachments shall not adversely interfere with the visibility of business signs or store fronts.
 - a. For attachments sanctioned by a municipality, disputes regarding such interference will be resolved by the municipality.

CLEARANCE

13. All clearances associated with pole attachments must be in accordance with the latest edition and supplements of the National Electric Safety Code (NESC), as well as any other state or municipal regulations.

GUYING

14. Attachers shall consult the Company regarding necessary guying when running cables between poles.

GROUNDING

15. Attachers shall consult the Company regarding necessary grounding for any electrified attachment—such as decorative lighting or lit signs—and ground as required by applicable regulations and Company determination.
16. For non-electric attachments, attachers shall ground as required by the Company.